

Building Renewal Grant Application

Initial Submission Date: 11/21/2012 3:02:13 PM

Application ID: 435

Resubmittal Date: 11/26/2012 11:38:18 AM

Please provide as much of the requested information as possible. SFB staff will assist in developing required information that is not currently available.

District Name: Scottsdale Unified District

Superintendent: David Peterson

Contact Person: Carlos Monreal

Contact Phone Number: 4804848519

Contact Email: cmonreal@susd.org

School Site: Saguaro High School

Buildings: 9999 School Wide

Description of Problem

Please include a detailed description of the issues, as well as a description of and a copy of any professional studies, citations or reports from government entities, recommended solutions, and any cost information or estimates. If additional space is needed, please attach.

5 year old 500 ton chiller had a rodent crawled into VSD (variable speed drive) compartment causing it to short-out both the filter circuit board and the trigger board, the trigger board must be replaced in order to further diagnose the full extent of the damage, the cost for the replacement for both circuit boards is \$ 10,697.00.

An additional scenario would be if one of the three pole assemblies is damaged, it would cost about \$25,000.00 each, and worst case scenario would be to replace entire VSD assembly at about \$80,000.00 At this time the chiller is not operational.

Project Category: HVAC

Are any of the above-described issues in buildings or part of buildings that are leased to another entity, including a district sponsored charter school? N

Available Funding

Current unencumbered building renewal fund balance (Fund 690):	\$0.00
Amount of Local funds planned for this project	\$0.00

Please outline any associated insurance coverage.

Liaison: Cruse

pcruse@azsfb.gov

602-364-1193

Superintendent Printed Name

7/2/2013 11:24:36 AM

Building Renewal Grant Application

Superintendent Signature

Date